

E Environment Committee

Item: 2012-274

For the Metropolitan Council meeting of September 26, 2012,

ADVISORY INFORMATION

Date Prepared: September 17, 2012

Subject: Authorization to Hold a Public Hearing on Draft Facility Plan for
Minneapolis Interceptor Rehabilitation, Phase 2, MCES Project No.
807625

Proposed Action:

It is recommended that the Metropolitan Council authorize its General Manager of Environmental Services to hold a public hearing for the Draft Facility Plan for the Minneapolis Interceptor Rehabilitation Project, Phase 2, MCES Project No. 807625.

Summary of Committee Discussion / Questions:

No issues were raised.

Motion to approve the proposed action was made, seconded, and passed unanimously.



Environment Committee

Business Item: 2012-274

Meeting date: September 11, 2012

For the Metropolitan Council Meeting of September 26, 2012

ADVISORY INFORMATION

Date:	August 21, 2012
Subject:	Authorization to Hold a Public Hearing on Draft Facility Plan for Minneapolis Interceptor Rehabilitation, Phase 2, MCES Project No. 807625
District(s), Member(s):	District 7, Gary Cunningham; District 8, Adam Duinick; District 13, Richard Kramer; District 14, Jon Commers
Policy/Legal Reference:	PFA Loan Requirement
Staff Prepared/Presented:	Scott Dentz 651-602-4503
Division/Department:	MCES c/o Leisa Thompson, 651-602-8101

Proposed Action

It is recommended that the Metropolitan Council authorize its General Manager of Environmental Services to hold a public hearing for the Draft Facility Plan for the Minneapolis Interceptor Rehabilitation Project, Phase 2, MCES Project No. 807625.

Background

A public hearing is required for a draft facility plan prior to its adoption by the Metropolitan Council as a condition for obtaining project financing through the Minnesota Public Financing Authority.

Rationale

Interceptor inspections and condition assessment have identified severe corrosion of Interceptor 1-MN-344 near Hiawatha Avenue (Highway 55) and Minnehaha Parkway. In addition, there is a need to improve several regulators (flow control structures) in Minneapolis. The proposed improvements will maintain and improve the integrity of MCES' facilities, minimize overflows that could pose a threat to public safety and health, and improve system reliability. The planning study assessed facility condition information, reviewed flow projections, identified and evaluated alternatives for improvements, and recommended an alternative to implement for each facility. The recommended alternatives consist of:

- Replacement of a segment of 1-MN-344 between regulator R04 and interceptor 1-MN-340.
- Reconstruction of regulator R04.
- Rehabilitate 1-MN-344 upstream of regulator R04 using cured-in-place pipe.
- Flow control, level monitoring, structural modifications, and rehabilitation improvements to the other eight regulators in Minneapolis.

Funding

Preliminary funds for the project's planning and design phase are included in the 2012 Capital Program. Construction authorization and funding are being requested in the proposed 2013 Capital Program. MCES will submit this project to PFA for inclusion in its 2014 Intended Use Plan.

Known Support / Opposition

MCES staff is not aware of opposition to the project.